



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY
WATER ANALYSIS REPORT

Report Issue Date: 09.01.2025

Customer Name & Address		Date of Receipt of Payment	04.01.2025	
St. Mary's Public School Thamarachal, Kizhakkambalam		Date of Sample received	06.01.2025	
		Sample Given by	MO I/C BFHC Malayidamthuruthu	
		Sample Code	ANK/BC 609/01/25	
		Sample Name	DRINKING WATER	
		Source of Sample	Well	
		Sample Quantity	200ml	
		Test performing dates : From: 07.01.2025 To: 08.01.2025		
Sl. No.	Source	No of Coliforms per 100ml of sample	E.Coli in 100ml of sample	
1	Water sample submitted by the customer	Absent	Absent	

Remarks:-

3:-The result stated above related only to the sample(s) submitted for testing by the customer .The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report

Authorized By

Bacteriologist SAJITHA SHEFEEK



KWA/QCSDL/ANK/01-2022		Issue Date : 01.06.2022	
Rev No:Nil	Rev,Date :Nil	Page 1of 1	

ST. MARY'S PUBLIC SCHOOL
THAMARACHAL

Manager

PRINCIPAL
ST. MARY'S PUBLIC SCHOOL
THAMARACHAL
KIZHAKKAMBALAM



Telephone:0484-2623576
email:-qcsdlankamaly@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY
WATER TEST REPORT

Report Issue Date: 09.01.2025

Customer Name & Address		Date of Receipt of Payment	04.01.2025		
St.Mary's Public School Thamarachal, Kizhakkambalam		Date of Sample received	06.01.2025		
		Sample Given by	MO I/C BFHC Malayidamthuruthu		
		Sample Code	ANK/58/01/2025		
		Sample Name	DRINKING WATER		
		Sample Condition	Good		
		Source of Sample	Well		
		Sample Quantity	2 Litre		
				Test performing dates : From: 07.01.2025 To: 08.01.2025	
Sl.No	Characteristics	Unit	Test Methods	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-1984(Reaffirmed 2017)	1.0	0.11
2	pH at 25°C	-	IS 3025 (Part 11)2022	6.5 to 8.5	7.5
3	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	24
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	12
5	Iron (as Fe)	mg/L	IS 3025(part 53) - 2003(Reaffirmed 2019)	1	BDL(DL=0.1)
6	Nitrate (as NO3)	mg/L	APHA 4500-NO3- B 2012	45	24.76
7	Electrical Conductivity	micromhos/cm	IS 3025(part14)-2013(Reaffirmed 2019)	-	104


Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report

ST. MARY'S PUBLIC SCHOOL
THAMARACHAL

Manager



Analysed By

FASEELA V S

Technical Manager

PRINCIPAL
ST. MARY'S PUBLIC SCHOOL
THAMARACHAL

KWA/QCSDL/ANK/F 21		Issue Date : 02.07.2021	
Rev No:02	Rev,Date :12/07/2023	Page 1 of 1	